



Senate Fiscal Agency
P.O. Box 30036
Lansing, Michigan 48909-7536

BILL ANALYSIS



Telephone: (517) 373-5383
Fax: (517) 373-1986

House Bill 4066 (Substitute H-1 as reported without amendment)
House Bill 4067 (Substitute H-1 as reported without amendment)
Sponsor: Representative Julie Calley
House Committee: Regulatory Reform
Senate Committee: Regulatory Reform

CONTENT

House Bill 4066 (H-1) and House Bill 4067 (H-1) would amend the Fire Prevention Code and the Single State Construction Code Act, respectively, to specify that a school that had a vestibule would not have to install a manual fire alarm box within the vestibule if a manual fire alarm box were located within five feet of the vestibule's interior door.

Proposed MCL 29.3d (H.B. 4066)
Proposed MCL 125.1504h (H.B. 4067)

Legislative Analyst: Drew Krogulecki

FISCAL IMPACT

The bills would have no fiscal impact on State or local government.

Date Completed: 5-15-19

Fiscal Analyst: Elizabeth Raczkowski